





Document Title: **EMC Test Report for:**
AZ/ALT Power Drive Unit
CASS Power Drive Unit
Data Acquisition Unit

Document Number: **VIS-PRO-VER-01001-9012**

Issue: **1.0**

Document Interpreted By:	Juan C. Delgadillo	Signature and Date:	 11 March 2005
Document Approved By:	Ed Reese	Signature and Date:	 11 March 2005
Document Released By:	Juan C. Delgadillo	Signature and Date:	 11 March 2005

The information contained in this document is strictly confidential and is intended for the addressee only. The unauthorised use, disclosure, copying, alteration or distribution of this document is strictly prohibited and may be unlawful.

ENGINEERING TEST REPORT

NUMBER: 4L0697EEU1

ON

Model No.(s):

Data Acquisition Unit
CASS Power Drive Unit
AZ/ALT Power Drive Unit

IN ACCORDANCE WITH:

EN 61000-6-4: 2001

&

EN 61000-6-2: 2001


TESTED FOR:

Vertex RSI
1219 Digital Dr.
Richardson, TX 75081

TESTED BY:

Nemko Dallas, Inc.
802 N. Kealy
Lewisville, Texas 75057-3136

APPROVED BY:


Arturo Ruvalcaba, EMC Engineer

DATE:

01/19/05



NVLAP LAB CODE: 100426-0

Table of Contents

Section 1.	Summary of Test Results	3
General:.....		3
Abstract:.....		3
Section 2.	Equipment Under Test (E.U.T.).....	6
Description of E.U.T.:.....		6
Modifications Incorporated in E.U.T.:.....		6
Justification:.....		7
Exercise Program:.....		7
E.U.T. Photographs:.....		9
Section 3.	Equipment Configuration.....	10
Equipment Configuration List:		10
Section 4.	Conducted Emissions (Mains ports)	11
Purpose:.....		11
Test Data –Conducted Emissions, Power Lines Test# CEPV-01		12
Test Data –Conducted Emissions, Power Lines Test# CEPV-02.....		16
Section 5.	Radiated Emissions.....	18
Purpose:.....		18
Test Data –Radiated Emissions, Electric Field, Test# REHE-01		19
Section 6.	Harmonics	28
Test Data –Harmonics Test# HARM-01		29
Test Data –Flicker Test# FLIC-01		37
Section 8.	Electrostatic Discharge Immunity.....	41
Test Data –Electrostatic Discharge Test# ESDI-01		42
Section 9.	Radiated Electromagnetic Immunity	46
Test Data –Radiated Electromagnetic Field Test# RIHE-01		47
Section 10.	Electrical Fast Transient / Burst.....	51
Test Data –Electrical Fast Transient / Burst Test# EFTP-01		52
Test Data –Electrical Fast Transient / Burst Test# EFTP-02.....		57
Test Data –Electrical Fast Transient / Burst Test# EFTI-01.....		61
Section 11.	Surge Immunity	64
Test Data –Surge Test# SGIP-01		65
Test Data –Surge Test# SGIP-02		68
Test Data –Surge Test# SGIP-03		72
Section 12.	RF Common Mode (A.M.)	74
Test Data –R.F. Common Mode (A.M.) Test# CIPC-01		75
Section 13.	Magnetic Immunity.....	79
Section 14.	Voltage Dips and Interruptions.....	80
Test Data –Voltage Dips and Interruptions Test# VDIP-01		81
Section 15.	Test Methods and Block Diagrams.....	85
Section 16.	Performance Criteria.....	97

Section 1. Summary of Test Results

General:

All measurements are traceable to national standards.

These tests were conducted on a sample of the equipment for the purpose of demonstrating compliance with the following standards:

- EN 61000-6-2: 2001, Generic standards – Immunity for industrial environments
- EN 61000-6-4 Generic standards – Emissions for industrial environments

All tests were performed using measurement procedure CISPR 16. Radiated emissions were performed on an open area test site.

Requirements and tests using the following standards as test methodologies:

Abstract:

Name of Test	Basic Standard	Results
Conducted Emissions (Mains port)	EN61000-6-4: 2001 (CISPR 11)	Complies
Radiated Emissions	EN61000-6-4: 2001 (CISPR 11)	Complies
Harmonics	EN61000-3-2: 2001	Complies
Flicker	EN61000-3-3: 2002	Complies

Abstract: Continued**Immunities:**

Name of Test	Basic Standard	Test Specification	Results
Electrostatic Discharge	EN61000-4-2: 1995	4kV Contact Discharge 8kV Air Discharge	Complies
Radiated Electro-magnetic Field	EN61000-4-3: 1996	80MHz to 1000 MHz 80% AM @ 1 kHz 10V/m	Complies
Electrical Fast Transients / Burst	EN61000-4-4: 1995	1 kV on I/O Signal and Control Lines 2kV on Power Supply	Complies
Surge Immunity	EN61000-4-5: 1995	I/O Surge 1 kV Line to Earth 2kV Line to Line 1kV	Complies
RF Conducted Immunity	EN61000-4-6: 1996	150 kHz to 80MHz 10 Vrms 80% Mod.	Complies
Magnetic Immunity	EN61000-4-8: 1993	30A/M @ 50Hz, 60Hz (For CRT 1A/M)	N/A
Voltage Dips and Interruptions	EN61000-4-11: 1994	30% Reduction (500ms) 60% Reduction (100ms) 60% Reduction (1000ms) <95% Reduction (5s)	Complies

Nemko Dallas, Inc.

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Nemko Dallas, Inc. authorizes the above named company to reproduce this report provided it is reproduced in its entirety, for use by the company's employees only.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Nemko Dallas, Inc. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

This report applies only to the item/s tested and does not constitute endorsement by the United States of America.

THE FOLLOWING DEVIATIONS FROM, ADDITIONS TO, OR EXCLUSIONS FROM THE TEST SPECIFICATIONS HAVE BEEN MADE: **NONE**

Section 2. Equipment Under Test (E.U.T.)

Manufacturer:	Vertex RSI
Name:	Model 133 Mount Control System
Model Number:	Data Acquisition Unit, VISTA
Part Number:	99-343-3300-001
Serial Number:	001
Model Number:	CASS Power Drive Unit, VISTA
Part Number:	99-343-2010-001
Serial Number:	001
Model Number:	AZ/ALT Power Drive Unit, VISTA
Part Number:	99-343-2000-001
Serial Number:	001
Production Status:	Production

Description of E.U.T.:

Motor Control System

Modifications Incorporated in E.U.T.:

The E.U.T. has not been modified from what is described by the brand name and unique type identification stated above.

Justification:

The E.U.T. was configured for testing as per typical installation. Position and bundling of cables were investigated to establish maximum amplitude of emissions.

The following combinations were investigated to establish worst-case configuration:
The AZ/ALT Power Drive Unit will be cabled to the four Azimuth Motors, to the Altitude test motor and the Regen Cabinet. The CASS Power Drive Unit will be cabled to the three CASS motors and to the Regeneration cabinet. The Data Acquisition Unit will be connected to the host computer and to three temperature sensors.
All cabinets powered and all motors running.

Exercise Program:

The E.U.T. exercise program used during radiated and conducted testing was designed to exercise the various system components in a manner similar to typical use.

The EUT was in the following exercise mode:

The Azimuth motors (4) and Altitude test motor (1) will be commanded (in rate loop mode) by the Portable Maintenance Unit to rate at LO rate. The Cassegrain motors will be commanded from the LCU Test Fixture to rotate at TRACK rate. The Data Acquisition Unit (DAQ) will establish communication with the Host Computer for the monitoring of 3 temperature sensors



Performance Criteria:

Criteria A: The apparatus shall continue to operate as intended. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer then either of these may be derived from the product description and documentation and what the user may reasonably expect from the apparatus if used as intended.

Criteria B: The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed. No change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer then either of these may be derived from the product description and documentation and what the user may reasonably expect from the apparatus if used as intended.

Criteria C: Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.

E.U.T. Photographs:



Section 3. Equipment Configuration

Equipment Configuration List:

EQUIPMENT CONFIGURATION LIST (HARDWARE/PERIPHERALS):

Place an "*" next to EUT and any item that is part of the EUT

Item	*	Generic Description	Manufacturer	Part No.	Serial #	Rev.	FCC ID Status ¹
(A)	*	AZ/ALT Power Drive Unit	Vertex RSI	99-343-2000-01	1	-	
(B)	*	CASS Power Drive Unit	Vertex RSI	99-343-2010-01	1	-	
(C)	*	Data Acquisition Unit	Vertex RSI	99-343-3300-01	1	-	
(D)		Isolation Transformer	Vertex RSI	99-343-4500-01	1	-	
(E)		Azimuth Drive Motors	Vertex RSI	99-343-3500-01	001-004	-	
(F)		Altitude Test Motor w/Encoder	Danaher				
(G)		CASS Drive Motors	Vertex RSI	99-343-3500-02	001-003	-	
(H)		Portable Maint Unit	Vertex RSI	99-343-3000-01	1	-	
(I)		Personal Computer	Generic		N/A		
(J)		LCU Test Fixture (for CASS)	Vertex RSI	--	N/A	-	
(K)		Regeneration Cabinet	Vertex RSI	99-343-2050-01	1	-	
(L)							

¹ FCC ID STATUS

1. FCC DOC

3. None - (If performing FCC testing, contact lab manager)

2. FCC A/B Verification

4. Certification (include FCC ID in parenthesis)

INTER-CONNECTION CABLES:

Place an "*" next to EUT and any item that is part of the EUT.

Item	*	Cable Type	Manufacturer	Ln (m)	Term ²	Shield	Qty.
(1)	*	4 Cond, 6 mm ²	Lapp USA Inc. (W13-W17, W67, W144, W147)	21-39	3	Y	5
(2)	*	4 Cond, 1.5 mm ²	Lapp USA Inc. (W19-W21, W145, W146)	44-55	3	y	3
(3)	*	2 TSP, 0.25mm ²	Lapp USA Inc. (W72-W73, W98-W100)	7-25	3	Y	5
(4)	*	8 TSP, 0.25 mm ²	Lapp USA, Inc. (W3-W6, W9-W11)	21-55	3	Y	7
(5)	*	25 Cond, 0.34 mm ²	Lapp USA, Inc. (W37)	4	3	Y	1
(6)		1X2X0.2mm ² + 1X2X0.32mm ²	Lapp USA, Inc. (W36)	10	5	Y	1
(7)	*	12 TSP, 0.25mm ²	Lapp USA, Inc. (W149)	8	3	Y	1
(8)							
(9)							
(10)							
(11)							
(12)							
(13)							

² TERMINATION

1. Peripheral

4. Resistive

2. Loopback

5. Remote Equipment

3. EUT

6. Other _____

Section 4. Conducted Emissions (Mains ports)

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to the limits for conducted disturbance as defined by EN61000-6-4: 2001.

Specification Limits:

Limits for conducted disturbance at the mains ports

Frequency Range MHz	Limits dB (μV)	
	Quasi-peak	Average
0.15 to 0.50	79	66
0.50 to 5.00	73	60
5.00-30.0	73	60

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test #:	CEPV-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	22°C
Date of Tests:	1/6/2005	Humidity:	38%

Test Results:

The E.U.T. complies.

The worst-case emission is 57.5 dBuV at 1.2 MHz on the Neutral side of the line.

This is 2.5 dB below the average specification limit of 60.0dBμV.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
545	LISN	Schwarz Beck	8120	8120350	09/17/04	09/17/05
968	Filter, High pass 5khz	Solartron	7930-5.0	933124	08/17/04	08/17/05
1115	CABLE, 4.5m	KTL	RG223	N/A	03/08/04	03/08/05
1547	CABLE .6m	KTL	RG223	N/A	06/09/04	06/09/05
718	HP SPECTRUM ANALYZER	HEWLETT PACKARD	8591EM	3639A00980	02/11/04	02/10/05
716	Receiver	Polorad	ESH2	879342/005	02/02/04	02/01/05

Test Data –Conducted Emissions, Power Lines Test# CEPV-01

[illegible]

Test Data Conducted Emissions, Power Lines Test# CEPV-01 Cont.

[illegible]

Test Data Conducted Emissions, Power Lines Test# CEPV-01 Cont.

[illegible]

Test Information:		Test Conditions:	
Test #:	CEPV-02	Test Voltage:	400Vac
Tested By:	J. Fish	Temperature:	22°C
Date of Tests:	1/6/2005	Humidity:	38%

Test Results:

The E.U.T. complies.

The worst-case emission is 58.1 dBuV at 0.86 MHz on the Hot side of the line.

This is 1.9 dB below the average specification limit of 60.0dB μ V.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
545	LISN	Schwarz Beck	8120	8120350	09/17/04	09/17/05
968	Filter, High pass 5khz	Solartron	7930-5.0	933124	08/17/04	08/17/05
1115	CABLE, 4.5m	KTL	RG223	N/A	03/08/04	03/08/05
1547	CABLE .6m	KTL	RG223	N/A	06/09/04	06/09/05
718	HP SPECTRUM ANALYZER	HEWLETT PACKARD	8591EM	3639A00980	02/11/04	02/10/05
716	Receiver	Polorad	ESH2	879342/005	02/02/04	02/01/05

Test Data –Conducted Emissions, Power Lines Test# CEPV-02

Conducted Emissions												
Powerline Voltage Measurement												
Complete	<u>X</u>		Job # : 4L0697E					Test # : CEPV-02				
Preliminary			Page 1					of 2				
Client Name :	Vertex RSI											
EUT Name :	CASS Power Drive Unit, VISTA											
EUT Model # :	Model 133 Mount Control System											
EUT Part # :	99-343-2010-01											
EUT Serial # :	001											
EUT Config. :	All cabinets powered and all motors running.											
Specification :	EN 61000-6-4											
Transducer # :	545	Temp. (deg. C) :	22									
HP Filter # :	968	Humidity (%) :	38									
Cable 1 # :	1115	EUT Voltage :	400Vac									
Cable 2 # :	1547	EUT Frequency :	50Hz									
Detector 1 # :	718	Peak Bandwidth :	10kHz									
Detector 2 # :	716	QP Bandwidth :	10kHz									
Limiter # :		Avg. Bandwidth :	10kHz									
Reference :												
Date :	01/06/05											
Time :	10:00											
Staff :	J. Fish											
Location :	SAC											
Photo ID :	4L0697E CEPV-02											

Meas Freq (MHz)	EUT Test Point	Detector Type (P, QP, A)	Limit Type (QP, A)	Meter Reading (dBuV)	Path Loss (dB)	Transducer Factor (dB)	Corrected Reading (dBuV)	Spec limit (dBuV)		CR/SL Diff (dB)	Pass Fail Unc.	Comment
								Q.P.	Avg.			
0.34	H	QP	QP	27.8	0	38.2	66.0	79	66	-13.0	Pass	
0.34	H	A	A	25.4	0	38.2	63.6	79	66	-2.4	Pass	
0.86	H	QP	QP	31.8	0	30.7	62.5	73	60	-10.5	Pass	
0.86	H	A	A	27.4	0	30.7	58.1	73	60	-1.9	Pass	
1.2	H	QP	QP	30.7	0	29.3	60.0	73	60	-13.0	Pass	
1.2	H	A	A	28.1	0	29.3	57.4	73	60	-2.6	Pass	
1.9	H	P	A	27.2	0	29.3	56.5	73	60	-3.5	Pass	
4.7	H	QP	QP	34.8	0	23.9	58.7	73	60	-14.3	Pass	
4.7	H	A	A	32.6	0	23.9	56.5	73	60	-3.5	Pass	
9.5	H	P	A	33.5	0	22.1	55.6	73	60	-4.4	Pass	
13.8	H	P	A	31.9	0	21.7	53.6	73	60	-6.4	Pass	
0.34	N	QP	QP	27.5	0	38.2	65.7	79	66	-13.3	Pass	
0.34	N	A	A	25.1	0	38.2	63.3	79	66	-2.7	Pass	
0.86	N	QP	QP	32.1	0	30.7	62.8	73	60	-10.2	Pass	
0.86	N	A	A	27.2	0	30.7	57.9	73	60	-2.1	Pass	
1.2	N	QP	QP	29.4	0	29.3	58.7	73	60	-14.3	Pass	
1.2	N	A	A	27.7	0	29.3	57.0	73	60	-3.0	Pass	
1.9	N	P	A	27.7	0	29.3	57.0	73	60	-3.0	Pass	
4.7	N	QP	QP	35.5	0	23.9	59.4	73	60	-13.6	Pass	
4.7	N	A	A	33.1	0	23.9	57.0	73	60	-3.0	Pass	
9.5	N	P	A	33.2	0	22.1	55.3	73	60	-4.7	Pass	
13.8	N	P	A	32.8	0	21.7	54.5	73	60	-5.5	Pass	

..EMCShare\AUTOMATE\DATASHTS\CEP_Voltage Rev C.xls Document Control #EMC_DS_EM_COND_VOLT

Test Data Conducted Emissions, Power Lines Test# CEPV-02 Cont.

[illegible]

Section 5. Radiated Emissions

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to the limits for radiated emissions as defined by EN61000-6-4: 2001.

Specification Limits:

Limits for radiated emissions.

Frequency range (MHz)	Quasi-peak Limits dB (μ V/m) @ 10 m
0.15 - 30	Under consideration
30 - 230	40
230 - 1000	47

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test # :	REHE-01	Test Voltage:	380
Tested By:	Kevin Rose	Temperature:	11°C
Date of Tests:	1/7/2005	Humidity:	80%

Test Results:

The E.U.T. complies.

The worst-case emission is 38.0 dB μ V/m at 48 MHz in the Vertical polarity.

This is 2.0 dB below the quasi-peak specification limit of 40.0dB μ V/m.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
760	Antenna biconical	Electro Metrics	MFC-25	477	06/22/04	06/22/05
759	ANTENNA, LOG PERIODIC	A.H. SYSTEMS	SAS-200/510	556	07/23/04	07/23/05
1518	Cable Assy, LAB 4 - C OATS	KTL	Site C OATS	N/A	03/11/04	03/11/05
791	PREAMP, 25dB	ICC	LNA25	398	11/12/04	11/12/05

Test Data –Radiated Emissions, Electric Field, Test# REHE-01

Radiated Emissions Data

Complete	X	Job # :	4L0697E	Test # :	REHE-01
Preliminary			Page 1	of	8
Client Name :	Vertex RSI				
EUT Name :	Data Acquisition Unit, VISTA; CASS Power Drive Unit, VISTA; AZ/ALT Power Drive Unit, VISTA				
EUT Model # :	Model 133 Mount Control System				
EUT Part # :	99-343-3300-01; 99-343-2010-01; 99-343-2000-01				
EUT Serial # :	001; 001; 001				
EUT Config :	All cabinets powered and all motors running.				
Specification :	CISPR 22: 1997, Class A		Reference :	EN 61000-6-4: 2001	
Rod Ant. # :		Temp. (deg C) :	11	Date :	01/07/05
Bicon Ant.# :	760	Humidity (%) :	80	Time :	8:00
Log Ant # :	759	EUT Voltage :	380	Staff :	Kevin Rose
Bilog Ant.# :		EUT Frequency :	50	Photo ID :	
Dipole Ant.# :		Phase :		Peak Bandwidth:	100 KHz
Cable# :	1518	Location :	C OATS	Video Bandwidth	100 KHz
Preamp# :	791	Distance :	10m		
Limiter# :	NA				
Atten # :	NA				
Detector# :					

Meas Freq (MHz)	Ant. Pol (H/V)	Atten (dB)	Meter Reading (dBuV)	Antenna Factor (dB)	Path Loss (dB)	RF Gain (dB)	Corrected Reading (dBuV/m)	Spec. limit (dBuV/m)	CR/SL Diff (dB)	Pass Fail Unc.	QP readings Comment
30	V	0	32.3	14.2	1.9	24.9	23.5	40.0	-16.5	Pass	Front
30.105	V	0	32.8	14.2	1.9	24.9	24.0	40.0	-16.0	Pass	Front
30.3	V	0	32.9	14.2	1.9	24.9	24.1	40.0	-15.9	Pass	Front
31.7	V	0	38.4	14.2	1.9	24.9	29.6	40.0	-10.4	Pass	Front
35.1	V	0	38.2	12.8	1.9	24.9	28.0	40.0	-12.0	Pass	Front
36.6	V	0	39.1	12.8	1.9	24.9	28.9	40.0	-11.1	Pass	Front
48	V	0	44.9	11	1.9	24.8	33.0	40.0	-7.0	Pass	Front
54	V	0	44.2	9.8	2.4	24.8	31.6	40.0	-8.4	Pass	Front
56.54	V	0	37	9.1	2.4	24.8	23.7	40.0	-16.3	Pass	Front
58.465	V	0	42.9	9.1	2.4	24.8	29.6	40.0	-10.4	Pass	Front
72.2	V	0	38.8	8.3	2.9	24.7	25.3	40.0	-14.7	Pass	Front
40	V	0	32.8	11.9	1.9	24.8	21.8	40.0	-18.2	Pass	Front
125.3	V	0	38.4	12.3	4.0	24.6	30.1	40.0	-9.9	Pass	Front
60	V	0	42	8.8	2.4	24.7	28.5	40.0	-11.5	Pass	Front
160	V	0	35.3	13.5	4.0	24.6	28.2	40.0	-11.8	Pass	Front
174	V	0	30	13.5	4.0	24.6	22.9	40.0	-17.1	Pass	Front
175.25	V	0	32.9	13.7	4.0	24.5	26.1	40.0	-13.9	Pass	Front
140	V	0	29.7	12.2	4.0	24.6	21.3	40.0	-18.7	Pass	Front
196.6	V	0	25.4	15.1	4.0	24.5	20.0	40.0	-20.0	Pass	Front
240	V	0	31.3	16.5	5.3	24.5	28.6	47.0	-18.4	Pass	Front
280	V	0	28.9	19.2	6.0	24.4	29.7	47.0	-17.3	Pass	Front

\\EMCShare\\AUTOMATE\\DATASHTS\\RADEMEV Rev C.xls Document Control #EMC DS EM RAD HFE

Test Data Radiated Emissions, Electric Field, Test# REHE-01 Cont.

Radiated Emissions Data												
Complete	<u> X </u>		Job # : <u> L0697E </u>		Test # : <u> REHE-01 </u>							
Preliminary	<u> </u>		Page <u> 2 </u>		of <u> 8 </u>							
Client Name :	<u> Vertex RSI </u>											
EUT Name :	<u> Data Acquisition Unit, VISTA; CASS Power Drive Unit, VISTA; AZ/ALT Power Drive Unit, VISTA </u>											
EUT Model # :	<u> Model 133 Mount Control System </u>											
EUT Part # :	<u> 99-343-3300-01; 99-343-2010-01; 99-343-2000-01 </u>											
EUT Serial # :	<u> 001; 001; 001 </u>											
EUT Config :	<u> All cabinets powered and all motors running. </u>											
Specification :	<u> CISPR 22: 1997, Class A </u>						Reference : <u> EN 61000-6-4: 2001 </u>					
Meas Freq (MHz)	Ant Pol (H/V)	Det Atten (dB)	Meter Reading (dBuV)	Antenna Factor (dB)	Path Loss (dB)	RF Gain (dB)	Corrected Reading (dBuV/m)	Spec limit (dBuV/m)	CR/SL Diff (dB)	Pass Fail Unc.	Comment	
320	V	0	25	16.2	6.7	24.4	23.5	47.0	-23.5	Pass	Front	
360	V	0	27.7	15.2	6.7	24.4	25.2	47.0	-21.8	Pass	Front	
400	V	0	20.9	16.4	8.0	24.4	20.9	47.0	-26.1	Pass	Front	
30	H	0	33.7	14.2	1.9	24.9	24.9	40.0	-15.1	Pass	Front	
30.105	H	0	33.2	14.2	1.9	24.9	24.4	40.0	-15.6	Pass	Front	
30.3	H	0	31.8	14.2	1.9	24.9	23.0	40.0	-17.0	Pass	Front	
31.7	H	0	34.6	14.2	1.9	24.9	25.8	40.0	-14.2	Pass	Front	
35.1	H	0	39	12.8	1.9	24.9	28.8	40.0	-11.2	Pass	Front	
36.6	H	0	36.1	12.8	1.9	24.9	25.9	40.0	-14.1	Pass	Front	
48	H	0	32.3	11	1.9	24.8	20.4	40.0	-19.6	Pass	Front	
54	H	0	30.4	9.8	2.4	24.8	17.8	40.0	-22.2	Pass	Front	
56.54	H	0	33.9	9.1	2.4	24.8	20.6	40.0	-19.4	Pass	Front	
58.465	H	0	33.4	9.1	2.4	24.8	20.1	40.0	-19.9	Pass	Front	
72.2	H	0	33.6	8.3	2.9	24.7	20.1	40.0	-19.9	Pass	Front	
40	H	0	28.9	11.9	1.9	24.8	17.9	40.0	-22.1	Pass	Front	
125.3	H	0	27.6	12.3	4.0	24.6	19.3	40.0	-20.7	Pass	Front	
60	H	0	32.7	8.8	2.4	24.7	19.2	40.0	-20.8	Pass	Front	
160	H	0	27.2	13.5	4.0	24.6	20.1	40.0	-19.9	Pass	Front	
174	H	0	23.2	13.5	4.0	24.6	16.1	40.0	-23.9	Pass	Front	
175.25	H	0	28.9	13.7	4.0	24.5	22.1	40.0	-17.9	Pass	Front	
140	H	0	23.5	12.2	4.0	24.6	15.1	40.0	-24.9	Pass	Front	
196.6	H	0	21.9	15.1	4.0	24.5	16.5	40.0	-23.5	Pass	Front	
240	H	0	28.9	16.5	5.3	24.5	26.2	47.0	-20.8	Pass	Front	
280	H	0	19.8	19.2	6.0	24.4	20.6	47.0	-26.4	Pass	Front	
320	H	0	23.8	16.2	6.7	24.4	22.3	47.0	-24.7	Pass	Front	
360	H	0	22.8	15.2	6.7	24.4	20.3	47.0	-26.7	Pass	Front	
400	H	0	21.5	16.4	8.0	24.4	21.5	47.0	-25.5	Pass	Front	

\\EMCShare\AUTOMATED\DATASHTS\RADEMEV Rev C xls Document Control #EMC DS EM RAD HFE

Test Data Radiated Emissions, Electric Field, Test# REHE-01 Cont.

[illegible]

Test Data Radiated Emissions, Electric Field, Test# REHE-01 Cont.

[illegible]

Test Data Radiated Emissions, Electric Field, Test# REHE-01 Cont.

[illegible]

Test Data Radiated Emissions, Electric Field, Test# REHE-01 Cont.

[illegible]

Test Data Radiated Emissions, Electric Field, Test# REHE-01 Cont.

Radiated Emissions Data

Complete X
Preliminary _____

Job #: L0697E Test #: REHE-01
Page 7 of 8

Client Name : Vertex RSI

EUT Name : Data Acquisition Unit, VISTA; CASS Power Drive Unit, VISTA; AZ/ALT Power Drive Unit, VISTA

EUT Model #: Model 133 Mount Control System

EUT Part #: 99-343-3300-01; 99-343-2010-01; 99-343-2000-01

EUT Serial #: 001; 001; 001

EUT Config : All cabinets powered and all motors running.

Specification : CISPR 22: 1997, Class A

Reference : EN 61000-6-4: 2001

[illegible]

\\EMCShare\AUTOMATE\DATASHTS\RADEMEV Rev C.xls

Document Control #EMC DS EM RAD HFE

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System



Test Data Radiated Emissions, Electric Field, Test# REHE-01 Cont.

Radiated Emissions Data												
Complete Preliminary		<u>X</u>		Job # : L0697E				Test # : REHE-01				
				Page <u>8</u>				of <u>8</u>				
Client Name : Vertex RSI												
EUT Name : Data Acquisition Unit, VISTA; CASS Power Drive Unit, VISTA; AZ/ALT Power Drive Unit, VISTA												
EUT Model # : Model 133 Mount Control System												
EUT Part # : 99-343-3300-01; 99-343-2010-01; 99-343-2000-01												
EUT Serial # : 001; 001; 001												
EUT Config : All cabinets powered and all motors running.												
Specification : CISPR 22: 1997, Class A				Reference : EN 61000-6-4: 2001								

Meas Freq (MHz)	Ant. Pol (H/V)	Det Atten. (dB)	Meter Reading (dBUV)	Antenna Factor (dB)	Path Loss (dB)	RF Gain (dB)	Corrected Reading (dBUV/m)	Spec. limit (dBUV/m)	CR/SL Diff (dB)	Pass Fail Unc.	Comment
30	H	0	31.2	14.2	1.9	24.9	22.4	40.0	-17.6	Pass	Right Side
30.105	H	0	32.6	14.2	1.9	24.9	23.8	40.0	-16.2	Pass	Right Side
30.3	H	0	35.2	14.2	1.9	24.9	26.4	40.0	-13.6	Pass	Right Side
31.7	H	0	34.2	14.2	1.9	24.9	25.4	40.0	-14.6	Pass	Right Side
35.1	H	0	31.9	12.8	1.9	24.9	21.7	40.0	-18.3	Pass	Right Side
36.6	H	0	35.6	12.8	1.9	24.9	25.4	40.0	-14.6	Pass	Right Side
48	H	0	31.2	11	1.9	24.8	19.3	40.0	-20.7	Pass	Right Side
54	H	0	33	9.8	2.4	24.8	20.4	40.0	-19.6	Pass	Right Side
56.54	H	0	33.6	9.1	2.4	24.8	20.3	40.0	-19.7	Pass	Right Side
58.465	H	0	29.9	9.1	2.4	24.8	16.6	40.0	-23.4	Pass	Right Side
72.2	H	0	26.3	8.3	2.9	24.7	12.8	40.0	-27.2	Pass	Right Side
40	H	0	33.3	11.9	1.9	24.8	22.3	40.0	-17.7	Pass	Right Side
125.3	H	0	26.3	12.3	4.0	24.6	18.0	40.0	-22.0	Pass	Right Side
60	H	0	35.7	8.8	2.4	24.7	22.2	40.0	-17.8	Pass	Right Side
160	H	0	21.9	13.5	4.0	24.6	14.8	40.0	-25.2	Pass	Right Side
174	H	0	21.3	13.5	4.0	24.6	14.2	40.0	-25.8	Pass	Right Side
175.25	H	0	21.6	13.7	4.0	24.5	14.8	40.0	-25.2	Pass	Right Side
140	H	0	19.8	12.2	4.0	24.6	11.4	40.0	-28.6	Pass	Right Side
196.6	H	0	20.1	15.1	4.0	24.5	14.7	40.0	-25.3	Pass	Right Side
240	H	0	21.5	16.5	5.3	24.5	18.8	47.0	-28.2	Pass	Right Side
280	H	0	20.9	19.2	6.0	24.4	21.7	47.0	-25.3	Pass	Right Side
320	H	0	23.3	16.2	6.7	24.4	21.8	47.0	-25.2	Pass	Right Side
360	H	0	21.3	15.2	6.7	24.4	18.8	47.0	-28.2	Pass	Right Side
400	H	0	22.1	16.4	8.0	24.4	22.1	47.0	-24.9	Pass	Right Side
											Scanned from 30MHz to 1GHz

\\EMCShare\AUTOMATE\DATASHTS\RADEMEVR Rev C xls Document Control #EMC DS EM RAD HFE

Test Photographs - Test # REHE-01



Section 6. Harmonics

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to the limits on the magnitude of harmonic currents created by the equipment, as specified in EN 61000-3-2: 2001.

Specification Limits:

For Class A equipment, the harmonics of the input current shall not exceed the maximum permissible values given in Table 1 multiplied by a factor of 1.5.

Table 1 – Limits for Class A equipment.

Harmonic order n	Maximum permissible Harmonic current A
Odd harmonics	
3	2.30
5	1.14
7	0.77
9	0.40
11	0.33
13	0.21
$15 \leq n \leq 39$	$0.15 \cdot 15/n$
Even harmonics	
2	1.08
4	0.43
6	0.30
$8 \leq n \leq 40$	$0.23 \cdot 8/n$

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test #:	HARM-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	23
Date of Tests:	12/21/04	Humidity:	39

Test Results:

The E.U.T. complies.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
793	Analyzer Harmonics	Combinova	300	115	1/9/04	1/9/05

Test Data - Harmonics Test# HARM-01

combinova ANALYZER 300 2004.12.22 06:19:57

Current Harmonics

Setup: 4L0635E Gen setting: 1(1) U: 229.69 V fu: 49.999 Hz
 Live Analysed periods: 4 I: 343.1 mA P: 41.2 W
 Module: M1 Limit: Class A (EN61000 A14) I1: 307.5 mA
 Note: THD=9.45% (PF=0.523) PASSED

No	A	Lim A	No	A	Lim A	No	A	Lim A
1	0.300		15	0.005	0.150	29	0.000	0.070
2	0.001	1.001	16	0.000	0.115	30	0.000	0.061
3	0.090	2.303	17	0.003	0.133	31	0.000	0.073
4	0.000	0.431	18	0.000	0.102	32	0.000	0.050
5	0.109	1.142	19	0.002	0.119	33	0.000	0.060
6	0.000	0.300	20	0.000	0.092	34	0.000	0.054
7	0.034	0.771	21	0.002	0.107	35	0.000	0.064
8	0.000	0.230	22	0.000	0.084	36	0.000	0.051
9	0.010	0.401	23	0.001	0.098	37	0.000	0.061
10	0.000	0.184	24	0.000	0.077	38	0.000	0.048
11	0.009	0.330	25	0.001	0.090	39	0.000	0.050
12	0.000	0.154	26	0.000	0.071	40	0.000	0.046
13	0.000	0.210	27	0.001	0.083			
14	0.000	0.132	28	0.000	0.066			

Current range: 1 Ap

Next measure
Change to bar graph
Relative current
Write to disk
1.2.1.2

Appl: DEFAULT



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary

Job #: 4L0697E Test #: HARM-01
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: Data Acquisition Unit, VISTA
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-343-3300-01
 EUT Serial #: 001
 EUT Config.: All cabinets powered and all motors running.

Specification: EN 61000-6-4
 Transducer #: 793 Temp. (deg. C): 23
 Power Supply#: 795 Humidity (%): 39
 EUT Voltage: 230Vac
 EUT Frequency: 50Hz

Reference: EN 6100-3-2
 Date: 12/21/2004
 Time: 8:00
 Staff: J. Fish
 Location: SAC
 Photo ID: 4L0697E HARM-01

Test Data - Harmonics Test# HARM-02

combinova ANALYZER 300 2004.12.22 06:19:12

Fluctuating Current Harmonics

Setup: 4L0635E Gen. setting: 1(1) U: 229.69 V fu: 49.999 Hz
 Live Analysed periods: 16 I: 342.7 mA P: 41.1 W
 Module: M1 Limit: Class A (EN61000 A11) I1: 306.7 mA
 LP-filter Note:

THD=19.44% (PF=0.522) **PASSED**

No	Mean A	Max A	Limit A	No	Mean A	Max A	Limit A
1	0.3067	0.3069		2	0.0011	0.0011	1.0000
3	0.0900	0.0900	2.3000	4	0.0005	0.0005	0.4300
5	0.1083	0.1084	1.1400	6	0.0000	0.0000	0.3000
7	0.0341	0.0341	0.7700	8	0.0001	0.0001	0.2300
9	0.0175	0.0176	0.4000	10	0.0000	0.0000	0.1840
11	0.0089	0.0090	0.3300	12	0.0001	0.0001	0.1533
13	0.0084	0.0084	0.2100	14	0.0000	0.0000	0.1314
15	0.0049	0.0049	0.1500	16	0.0000	0.0000	0.1150
17	0.0031	0.0031	0.1324	18	0.0000	0.0000	0.1022
19	0.0024	0.0024	0.1104	20	0.0000	0.0000	0.0920

(Next page, Press 'arrow down' > 1 s)

Appl: DEFAULT 1.2.1.5

Next measure

Select module

Voltage check




Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary

Job #: 4L0697E Test #: HARM-02
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: Data Acquisition Unit, VISTA
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-343-3300-01
 EUT Serial #: 001
 EUT Config.: All cabinets powered and all motors running.

Specification: EN 61000-6-4
 Transducer #: 793 Temp. (deg. C): 23
 Power Supply#: 795 Humidity (%): 39
 EUT Voltage: 230Vac
 EUT Frequency: 50Hz

Reference: EN 61000-3-2
 Date: 12/21/2004
 Time: 8:00
 Staff: J. Fish
 Location: SAC
 Photo ID: 4L0697E HARM-01

Test Data - Harmonics Test# HARM-03

combinova ANALYZER 300 2004.12.28 02:17:31

Current Harmonics

Setup: 4L0635E Gen setting: 1(1) U : 229.71 V fu: 49.999 Hz
 Live Analysed periods: 4 I : 1.174 A P: 0.136 kW
 Module: M1 Limit: Class A (EN61000 A14) I1: 0.745 A
 Note:
 THD=121.92 % (PF=0.506) PASSED

No	A	Lim A	No	A	Lim A	No	A	Lim A
1	0.745		15	0.069	0.150	29	0.005	0.078
2	0.011	1.081	16	0.000	0.115	30	0.000	0.061
3	0.527	2.303	17	0.022	0.133	31	0.011	0.073
4	0.002	0.431	18	0.000	0.102	32	0.000	0.058
5	0.470	1.141	19	0.021	0.119	33	0.015	0.068
6	0.001	0.300	20	0.000	0.092	34	0.000	0.054
7	0.394	0.771	21	0.033	0.107	35	0.014	0.064
8	0.000	0.230	22	0.000	0.084	36	0.000	0.051
9	0.307	0.401	23	0.033	0.098	37	0.010	0.061
10	0.000	0.184	24	0.000	0.077	38	0.000	0.048
11	0.219	0.330	25	0.025	0.090	39	0.005	0.050
12	0.000	0.154	26	0.000	0.071	40	0.000	0.046
13	0.137	0.210	27	0.013	0.083			
14	0.000	0.132	28	0.000	0.066			

Current range: 10 Ap

Appl: DEFAULT 1.2.1.2

Next measure
Change to bar graph
Relative current
Write to disk



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary _____

Job #: 4L0697E Test #: HARM-03
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: CASS Power Drive Unit
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-2010-01
 EUT Serial #: 001
 EUT Config: All cabinets powered and all motors running.

Specification: EN 61000-6-4
 Transducer #: 793 Temp. (deg. C): 23
 Power Supply#: 795 Humidity (%): 39
 EUT Voltage: 230Vac
 EUT Frequency: 50Hz

Reference: EN 6100-3-2
 Date: 12/21/2004
 Time: 8:00
 Staff: J. Fish
 Location: SAC
 Photo ID: 4L0697E HARM-01

Test Data – Harmonics Test# HARM-04

combinova ANALYZER 300 2004.12.28 02:16:36

Fluctuating Current Harmonics

Setup: 4L0635E Gen setting: 1(1) U: 229.72 V fu: 49.999 Hz
 Live Analysed periods: 16 I: 1.174 A P: 0.136 kW
 Module: M1 Limit: Class A (EN61000 A14) IT: 0.743 A
 LP-filter Note:

THD=121.98 % (PF=0.505) PASSED

No	Mean A	Max A	Limit A	No	Mean A	Max A	Limit A
1	0.743	0.743		2	0.011	0.011	1.000
3	0.526	0.526	2.300	4	0.002	0.002	0.430
5	0.469	0.469	1.140	6	0.001	0.001	0.300
7	0.393	0.393	0.770	8	0.000	0.000	0.230
9	0.307	0.307	0.400	10	0.000	0.001	0.104
11	0.219	0.219	0.330	12	0.000	0.000	0.153
13	0.137	0.137	0.210	14	0.000	0.000	0.131
15	0.069	0.069	0.150	16	0.000	0.000	0.115
17	0.022	0.022	0.132	18	0.000	0.000	0.102
19	0.021	0.021	0.110	20	0.000	0.000	0.092

(Next page, Press 'arrow down' > 1 s)

App1: DEFAULT 1.2.1.5

Next measure
Select module
Voltage check



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary

Job #: 4L0697E Test #: HARM-04
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: CASS Power Drive Unit
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-2010-01
 EUT Serial #: 001
 EUT Config.: All cabinets powered and all motors running.

Specification: EN 61000-6-4
 Transducer #: 793 Temp. (deg. C): 23
 Power Supply#: 795 Humidity (%): 39
 EUT Voltage: 230Vac
 EUT Frequency: 50Hz

Reference: EN 6100-3-2
 Date: 12/21/2004
 Time: 8:00
 Staff: J. Fish
 Location: SAC
 Photo ID: 4L0697E HARM-01

Test Data - Harmonics Test# HARM-05

combinova ANALYZER 300 2004.12.20 05:27:22

Current Harmonics

Setup: 4L0635E Gen setting: 1(1) U: 229.50 V fu: 49.999 Hz
 Live Analysed periods: 4 I: 2.431 A P: 0.331 kW
 Module: M1 Limit: Class A (EN61000-6-4) IT: 1.692 A
 Note:
 THD=103.15 % (PF=0.594) PASSED

No	A	Lim A	No	A	Lim A	No	A	Lim A
1	1.692		15	0.048	0.150	29	0.006	0.070
2	0.004	1.002	16	0.000	0.115	30	0.000	0.061
3	1.241	2.305	17	0.048	0.133	31	0.004	0.073
4	0.001	0.431	18	0.000	0.102	32	0.000	0.058
5	0.955	1.142	19	0.025	0.119	33	0.004	0.068
6	0.002	0.301	20	0.000	0.092	34	0.000	0.054
7	0.647	0.772	21	0.012	0.107	35	0.010	0.064
8	0.001	0.231	22	0.000	0.084	36	0.000	0.051
9	0.375	0.401	23	0.011	0.098	37	0.009	0.061
10	0.001	0.184	24	0.000	0.077	38	0.000	0.049
11	0.163	0.331	25	0.006	0.090	39	0.002	0.058
12	0.000	0.154	26	0.000	0.071	40	0.000	0.046
13	0.033	0.210	27	0.002	0.084			
14	0.000	0.132	28	0.000	0.066			

Current range: 10 Ap

Appl: DEFAULT 1.2.1.2

Next measure
Change to bar graph
Relative current
Write to disk



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary _____

Job #: 4L0697E Test #: HARM-05
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: AZ/ALT Power Drive Unit, VISTA
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-343-2000-01
 EUT Serial #: 001
 EUT Config.: All cabinets powered and all motors running.

Specification: EN 61000-6-4 Reference: EN 6100-3-2
 Transducer #: 793 Temp. (deg. C): 23 Date: 12/21/2004
 Power Supply#: 795 Humidity (%): 39 Time: 8:00
 EUT Voltage: 230Vac Staff: J. Fish
 EUT Frequency: 50Hz Location: SAC
 Photo ID: 4L0697E FLIC-01

Test Data - Harmonics Test# HARM-06

combinova ANALYZER 300 2004.12.28 05:26:39

Fluctuating Current Harmonics

Setup: 4L0635E Gen setting: 1(1) U: 229.49 V fu: 49.999 Hz
 Live Analysed periods: 16 I: 2.480 A P: 0.340 kW
 Module: M1 Limit: Class A (EN61000 A14) I1: 1.721 A
 LP-filter Note

THD=103.44 % (PF=0.597) PASSED

No	Mean A	Max A	Limit A	No	Mean A	Max A	Limit A
1	1.721	1.721		2	0.004	0.005	1.000
3	1.270	1.271	2.300	4	0.001	0.002	0.430
5	0.974	0.975	1.140	6	0.002	0.002	0.300
7	0.656	0.656	0.770	8	0.001	0.001	0.230
9	0.376	0.377	0.400	10	0.001	0.001	0.104
11	0.160	0.160	0.330	12	0.000	0.000	0.153
13	0.031	0.031	0.210	14	0.000	0.000	0.131
15	0.049	0.049	0.150	16	0.000	0.000	0.115
17	0.048	0.048	0.132	18	0.000	0.000	0.102
19	0.024	0.024	0.118	20	0.000	0.000	0.092

(Next page, Press arrow down > 1 s)

Measurement completed (600s) Appl: DEFAULT 1.2.1.5

Next measure

Select module

Voltage check



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary

Job #: 4L0697E Test #: HARM-06
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: AZ/ALT Power Drive Unit, VISTA
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-343-2000-01
 EUT Serial #: 001
 EUT Config.: All cabinets powered and all motors running.

Specification: EN 61000-6-4
 Transducer #: 793 Temp. (deg. C): 23
 Power Supply#: 795 Humidity (%): 39
 EUT Voltage: 230Vac
 EUT Frequency: 50Hz

Reference: EN 6100-3-2
 Date: 12/21/2004
 Time: 8:00
 Staff: J. Fish
 Location: SAC
 Photo ID: 4L0697E FLIC-01

Test Photographs - Test # HARM-01



Section 7. Flicker

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to the limits on the level of voltage fluctuations produced by the equipment, as specified in EN 61000-3-3: 2002.

Specification Limits:

The limits shall be applicable to voltage fluctuations and flicker at the supply terminals of the equipment under test.

The following limits apply:

- The value of P_{st} shall not be greater than 1.0.
- The value of P_{It} shall not be greater than 0.65.
- The relative steady-state voltage change, d_c , shall not exceed 3%.
- The maximum relative voltage change, d_{max} , shall not exceed 4%.
- The value of $d(t)$ during a voltage change shall not exceed 3% for more than 200 ms.

If voltage changes are caused by manual switching or occur less frequently than once per hour, the P_{st} and P_{It} requirements shall not be applicable. The three requirements related to voltage changes shall be applicable with the previously mentioned voltage values, multiplied by a factor of 1.33.

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test # :	FLIC-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	23
Date of Tests:	12/21/04	Humidity:	39

Test Results:

The E.U.T. complies

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
793	Analyzer Harmonics	Combinova	300	115	1/9/04	1/9/05

Test Data -Flicker Test# FLIC-01

combinova		ANALYZER 300		2004.12.22 06:00:46	
Extreme Flicker-I M1					Next measure
Note: Numerical Reference Impedance U: 229.7 V I: 342.6 mA f: 49.998 Hz PF: 0.522					
EVALUATION: Type of observation period Observation time Maximum relative voltage change Max rel steady state voltage change Duration of d(t) > 3 % Short term flicker severity Long term flicker severity Based on 12 (12) short term cycles					Extreme time graph Change to histogram Write to disk Select module
	Short	Long	Limit		
tp	10	120 min			
dmax		0.00 %	4		
dc		0.00 %	3		
t		0.00 s	0.2		
Pst		0.00	1.00		
Plt		0.00	0.65		
PASSED					
Measurement completed					
Appl: DEFAULT					1.3.1.1



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary

Job #: 4L0697E Test #: FLIC-01
 Page 1 of 1

Client Name : Vertex RSI
 EUT Name : Data Acquisition Unit, VISTA
 EUT Model # : Model 133 Mount Control System
 EUT Part # : 99-343-3300-01
 EUT Serial # : 001
 EUT Config : All cabinets powered and all motors running.

Specification :	EN 61000-6-4	Reference :	EN 6100-3-2
Transducer # :	793	Date :	12/21/2004
Power Supply# :	795	Time :	8:00
	Temp (deg. C) :	Staff :	J. Fish
	Humidity (%) :	Location :	SAC
	EUT Voltage :	Photo ID :	4L0697E FLIC-01
	EUT Frequency :		

Test Data - Flicker Test# FLIC-02

combinova		ANALYZER 300	2004.12.28 01:24:26																												
Extreme Flicker-I M1			Next measure																												
Note: Numerical Reference Impedance U: 229.8 V I: 1.177 A f: 49.998 Hz PF: 0.505																															
EVALUATION: Type of observation period Observation time Maximum relative voltage change Max rel steady state voltage change Duration of d(t) > 3 % Short term flicker severity Long term flicker severity Based on 12 (12) short term cycles.			Extreme time graph Change to histogram Write to disk Select module																												
<table border="1"> <thead> <tr> <th></th> <th>Short</th> <th>Long</th> <th>Limit</th> </tr> </thead> <tbody> <tr> <td>tp</td> <td>10</td> <td>120 min</td> <td></td> </tr> <tr> <td>dmax</td> <td></td> <td>0.00 %</td> <td>4</td> </tr> <tr> <td>dc</td> <td></td> <td>0.00 %</td> <td>3</td> </tr> <tr> <td>t</td> <td></td> <td>0.00 s</td> <td>0.2</td> </tr> <tr> <td>Pst</td> <td></td> <td>0.00</td> <td>1.00</td> </tr> <tr> <td>Plt</td> <td></td> <td>0.00</td> <td>0.65</td> </tr> </tbody> </table>				Short	Long	Limit	tp	10	120 min		dmax		0.00 %	4	dc		0.00 %	3	t		0.00 s	0.2	Pst		0.00	1.00	Plt		0.00	0.65	
	Short	Long	Limit																												
tp	10	120 min																													
dmax		0.00 %	4																												
dc		0.00 %	3																												
t		0.00 s	0.2																												
Pst		0.00	1.00																												
Plt		0.00	0.65																												
PASSED																															
Measurement completed																															
Appl: DEFAULT			1.3.1.1																												



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary _____

Job #: 4L0697E Test #: FLIC-02
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: CASS Power Drive Unit
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-2010-01
 EUT Serial #: 001
 EUT Config.: All cabinets powered and all motors running.

Specification:	EN 61000-6-4	Reference:	EN 6100-3-3
Transducer #:	793	Date:	12/21/2004
Power Supply#:	795	Time:	8:00
	Temp. (deg. C): 23	Staff:	J. Fish
	Humidity (%): 39	Location:	SAC
	EUT Voltage: 230Vac	Photo ID:	4L0697E FLIC-01
	EUT Frequency: 50Hz		

Test Data -Flicker Test# FLIC-03

combinova		ANALYZER 300	2004.12.28 04:43:26
Extreme Flicker-I M1			Next measure
Note: Numerical Reference Impedance U: 229.5 V I: 2.480 A f: 49.998 Hz PF: 0.597			
EVALUATION: Type of observation period Observation time Maximum relative voltage change Max rel steady state voltage change Duration of d(t) > 3 % Short term flicker severity Long term flicker severity Based on 12 (12) short term cycles:			Extreme time graph Change to histogram Write to disk Select module
	Short	Long	Limit
tp	10	120 min	
dmax	0.00 %		4
dc	0.00 %		3
t	0.00 s		0.2
Pst	0.00		1.00
Plt	0.00		0.65
PASSED			
Measurement completed			
Appl: DEFAULT			1.3.1.1



Dallas Headquarters:

802 N. Kealy
 Lewisville, TX 75057
 Tel: (972) 436-9600
 Fax: (972) 436-2667

Complete X
 Preliminary _____

Job #: 4L0697E Test #: FLIC-03
 Page 1 of 1

Client Name: Vertex RSI
 EUT Name: AZ/ALT Power Drive Unit, VISTA
 EUT Model #: Model 133 Mount Control System
 EUT Part #: 99-343-2000-01
 EUT Serial #: 001
 EUT Config.: All cabinets powered and all motors running.

Specification:	EN 61000-6-4		Reference:	EN 6100-3-3	
Transducer #:	793	Temp. (deg. C):	23	Date:	12/21/2004
Power Supply#:	795	Humidity (%):	39	Time:	8:00
		EUT Voltage:	230Vac	Staff:	J. Fish
		EUT Frequency:	50Hz	Location:	SAC
				Photo ID:	4L0697E FLIC-01

Test Photographs - Test # FLIC-01



Section 8. Electrostatic Discharge Immunity

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to electrostatic discharges.

Minimum Performance Criteria B

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test # :	ESDI-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	22°C
Date of Tests:	12/23/05	Humidity:	41%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
560	ESD Simulator	Keytek	MZ-15/AC	9205392	02/10/04	02/09/05

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data –Electrostatic Discharge Test# ESDI-01

[illegible]

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data Electrostatic Discharge Test# ESDI-01 Cont.

[illegible]

& EN61000-6-4: 2001

EN61000-6-2: 2001


REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data Electrostatic Discharge Test# ESDI-01 Cont.

[illegible]

Test Photographs - Test # ESDI-01



Section 9. Radiated Electromagnetic Immunity

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to radiated electromagnetic field energy.

Minimum Performance Criteria A

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test #:	RIHE-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	22°C
Date of Tests:	12/23/04	Humidity:	35%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
729	SIGNAL GENERATOR	HP	8656A	2402A05973	CNR	N/A
573	CABLE, 5.5m	KTL	RG213	N/A	02/05/04	02/04/05
970	CABLE, 14.8m	KTL	RG223	N/A	06/09/04	06/09/05
412	RF AMPLIFIER	Amplifier Research	100W1000M1A	21233	CNR	N/A
1131	Biological antenna	A.H. Systems	SAS-200/521	0	CNR	N/A
718	HP SPECTRUM ANALYZER	HEWLETT PACKARD	8591EM	3639A00980	02/11/04	02/10/05

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data –Radiated Electromagnetic Field Test# RIHE-01

[illegible]

EQUIPMENT: Model 133 Mount Control System

Radiated Immunity Electric Field Test Data

Complete	X	Job # : 4L0697E	Test # : RIHE-01
Preliminary		Page 1	of 1
Client Name :	Vertex RSI		
EUT Name :	CASS Power Drive Unit, VISTA		
EUT Model # :	Model 133 Mount Control System		
EUT Part # :	99-343-2010-01		
EUT Serial # :	001		
EUT Config :	All cabinets powered and all motors running.		
Specification :	EN 61000-6-2		
Signal Gen #:	729	Temp (deg. C) :	22
Signal Gen.#:		Humidity (%) :	35
Cable#:	749	EUT Voltage :	230Vac
Cable#:	970	EUT Frequency :	60Hz
Cable#:		Phase:	1
Amp#:	412	Location:	SAC
Amp#:		Monitor Probe#:	
Amp#:		Field Monitor#:	
Amp#:		Power Meter#:	
Antenna#:	1131	Spectrum Analyzer#	718
Antenna#:			
		Reference :	EN 61000-4-6
		Date :	12/23/04
		Time :	2:00
		Staff :	J. Fish
		Photo ID:	4L0697E RIHE-01
		Performance Criteria:	A
		Table Top or Floor:	Floor
		Sweep rate:	
		Step Size:	1%
		Modulated:	80%

[illegible]


\\EMCShare\\AUTOMATE\\DATASHTS\\Radiated Immunity Electric Rev C.xls

Document Control #EMC DS IM RAD ELEC

Test Data Radiated Electromagnetic Field Test# RIHE-01 Cont.

[illegible]

Test Photographs - Test # RIHE-01



Section 10. Electrical Fast Transient / Burst**Purpose:**

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to repetitive electrical fast transients (bursts), on supply, signal, or control lines.

Minimum Performance Criteria B

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test # :	EFTP-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	24°C
Date of Tests:	12/20/05	Humidity:	36%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
590	PEFT (EFT generator)	Haefely	DGFT junior	589071-03	02/02/04	02/01/05
559	Capacitive clamp	ICC	0	0	CNR	N/A

Test Data –Electrical Fast Transient / Burst Test# EFTP-01

Electrically Fast Transient Data									
Complete	<u> X </u>			Job # : 4L0697E			Test # : EFTP-01		
Preliminary	<u> </u>			Page <u> 1 </u>			of <u> 3 </u>		
Client Name :	Vertex RSI								
EUT Name :	Data Acquisition Unit, VISTA								
EUT Model # :	Model 133 Mount Control System								
EUT Part # :	99-343-3300-01								
EUT Serial # :	001								
EUT Config. :	All cabinets powered and all motors running.								
Specification :	EN 61000-6-2			Reference :			EN 61000-4-4		
Generator#:	590		Temp. (deg. C) :	24		Date :	12/20/05		
Clamp#:	559		Humidity (%) :	36		Time :	2:00		
Probe#:	NA		EUT Voltage :	230Vac		Staff :	J. Fish		
1. L	<u> X </u>		EUT Frequency :	60Hz		Photo ID:	4L0697E EFTP-01		
2. N	<u> X </u>		Phase:	1		Performance Criteria:	B		
3. PE	<u> X </u>		Location:	SAC		Table Top or Floor	Floor		
4. L+N	<u> X </u>		7. L+N+PE	<u> X </u>		10	<u> </u>		
5. L+PE	<u> X </u>		8.	<u> </u>		11	<u> </u>		
6. N+PE	<u> X </u>		9.	<u> </u>		12	<u> </u>		

Test Point	EFT Level (kV)	Direct or Capacitive	Polarity	Time Duration	Effects Number	Effects Type	Pass or Fail	Comments:
1	0.5	Direct	+/-	2	0	N/A	Pass	Logic Power
2	0.5	Direct	+/-	2	0	N/A	Pass	
3	0.5	Direct	+/-	2	0	N/A	Pass	
4	0.5	Direct	+/-	2	0	N/A	Pass	
5	0.5	Direct	+/-	2	0	N/A	Pass	
6	0.5	Direct	+/-	2	0	N/A	Pass	
7	0.5	Direct	+/-	2	0	N/A	Pass	
1	1	Direct	+/-	2	0	N/A	Pass	
2	1	Direct	+/-	2	0	N/A	Pass	
3	1	Direct	+/-	2	0	N/A	Pass	
4	1	Direct	+/-	2	0	N/A	Pass	
5	1	Direct	+/-	2	0	N/A	Pass	
6	1	Direct	+/-	2	0	N/A	Pass	
7	1	Direct	+/-	2	0	N/A	Pass	
1	2	Direct	+/-	2	0	N/A	Pass	
2	2	Direct	+/-	2	0	N/A	Pass	
3	2	Direct	+/-	2	0	N/A	Pass	
4	2	Direct	+/-	2	0	N/A	Pass	
5	2	Direct	+/-	2	0	N/A	Pass	
6	2	Direct	+/-	2	0	N/A	Pass	
7	2	Direct	+/-	2	0	N/A	Pass	

\\EMCShare\AUTOMATE\DATASHTS\EFT Rev C.xls Document Control #EMC DS IM EFT

Test Data Electrical Fast Transient / Burst Test# EFTP-01 Cont.

Electrically Fast Transient Data									
Complete	<u> X </u>			Job # : 4L0697E			Test # : EFTP-01		
Preliminary	<u> </u>			Page <u> 1 </u>			of <u> 3 </u>		
Client Name :	Vertex RSI								
EUT Name :	CASS Power Drive Unit, VISTA								
EUT Model # :	Model 133 Mount Control System								
EUT Part # :	99-343-2010-01								
EUT Serial # :	001								
EUT Config. :	All cabinets powered and all motors running.								
Specification :	EN 61000-6-2			Reference : EN 61000-4-4					
Generator#:	590		Temp. (deg. C) :	24		Date :	12/20/05		
Clamp#:	559		Humidity (%) :	36		Time :	2:00		
Probe#:	NA		EUT Voltage :	230Vac		Staff :	J. Fish		
1. L	<u> X </u>		EUT Frequency :	60Hz		Photo ID:	4L0697E EFTP-01		
2. N	<u> X </u>		Phase:	1		Performance Criteria:	B		
3. PE	<u> X </u>		Location:	SAC		Table Top or Floor	Floor		
4. L+N	<u> X </u>		7. L+N+PE	<u> X </u>		10	<u> </u>		
5. L+PE	<u> X </u>		8.	<u> </u>		11	<u> </u>		
6. N+PE	<u> X </u>		9.	<u> </u>		12	<u> </u>		

Test Point	EFT Level (kV)	Direct or Capacitive	Polarity	Time Duration	Effects Number	Effects Type	Pass or Fail	Comments:
1	0.5	Direct	+/-	2	0	N/A	Pass	Logic Power
2	0.5	Direct	+/-	2	0	N/A	Pass	
3	0.5	Direct	+/-	2	0	N/A	Pass	
4	0.5	Direct	+/-	2	0	N/A	Pass	
5	0.5	Direct	+/-	2	0	N/A	Pass	
6	0.5	Direct	+/-	2	0	N/A	Pass	
7	0.5	Direct	+/-	2	0	N/A	Pass	
1	1	Direct	+/-	2	0	N/A	Pass	
2	1	Direct	+/-	2	0	N/A	Pass	
3	1	Direct	+/-	2	0	N/A	Pass	
4	1	Direct	+/-	2	0	N/A	Pass	
5	1	Direct	+/-	2	0	N/A	Pass	
6	1	Direct	+/-	2	0	N/A	Pass	
7	1	Direct	+/-	2	0	N/A	Pass	
1	2	Direct	+/-	2	0	N/A	Pass	
2	2	Direct	+/-	2	0	N/A	Pass	
3	2	Direct	+/-	2	0	N/A	Pass	
4	2	Direct	+/-	2	0	N/A	Pass	
5	2	Direct	+/-	2	0	N/A	Pass	
6	2	Direct	+/-	2	0	N/A	Pass	
7	2	Direct	+/-	2	0	N/A	Pass	

\\EMCShare\AUTOMATE\DATASHTS\EFT Rev C.xls Document Control #EMC DS IM EFT


Test Data Electrical Fast Transient / Burst Test# EFTP-01 Cont.

Electrically Fast Transient Data									
Complete	X				Job # 4L0697E	Test # EFTP-01			
Preliminary					Page 1	of 3			
Client Name : Vertex RSI									
EUT Name : AZ/ALT Power Drive Unit, VISTA									
EUT Model # : Model 133 Mount Control System									
EUT Part # : 99-343-2000-01									
EUT Serial # : 001									
EUT Config : All cabinets powered and all motors running.									
Specification : EN 61000-6-2									
Reference : EN 61000-4-4									
Generator#:	590	Temp (deg C):	24	Date:	12/20/05				
Clamp#:	559	Humidity (%):	36	Time:	2:00				
Probe#:	NA	EUT Voltage:	230Vac	Staff:	J. Fish				
1 L	X	EUT Frequency:	60Hz	Photo ID:	4L0697E EFTP-01				
2 N	X	Phase:	1	Performance Criteria:	B				
3 PE	X	Location:	SAC	Table Top or Floor	Floor				
4 L+N	X	7 L+N+PE	X	10.					
5 L+PE	X	8		11					
6 N+PE	X	9		12					

Test Point	EFT Level (kV)	Direct or Capacitive	Polarity	Time Duration	Effects Number	Effects Type	Pass or Fail	Comments:
1	0.5	Direct	+/-	2	0	N/A	Pass	Logic Power
2	0.5	Direct	+/-	2	0	N/A	Pass	
3	0.5	Direct	+/-	2	0	N/A	Pass	
4	0.5	Direct	+/-	2	0	N/A	Pass	
5	0.5	Direct	+/-	2	0	N/A	Pass	
6	0.5	Direct	+/-	2	0	N/A	Pass	
7	0.5	Direct	+/-	2	0	N/A	Pass	
1	1	Direct	+/-	2	0	N/A	Pass	
2	1	Direct	+/-	2	0	N/A	Pass	
3	1	Direct	+/-	2	0	N/A	Pass	
4	1	Direct	+/-	2	0	N/A	Pass	
5	1	Direct	+/-	2	0	N/A	Pass	
6	1	Direct	+/-	2	0	N/A	Pass	
7	1	Direct	+/-	2	0	N/A	Pass	
1	2	Direct	+/-	2	0	N/A	Pass	
2	2	Direct	+/-	2	0	N/A	Pass	
3	2	Direct	+/-	2	0	N/A	Pass	
4	2	Direct	+/-	2	0	N/A	Pass	
5	2	Direct	+/-	2	0	N/A	Pass	
6	2	Direct	+/-	2	0	N/A	Pass	
7	2	Direct	+/-	2	0	N/A	Pass	

..EMCShare\AUTOMATE\DATASHTS\EFT Rev C.xls Document Control #EMC DS IM EFT

Test Photographs - Test # EFTP-01



Nemko Dallas, Inc.

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Information:		Test Conditions:	
Test # :	EFTP-02	Test Voltage:	400Vac
Tested By:	J. Fish	Temperature:	24°C
Date of Tests:	12/20/05	Humidity:	36%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
590	PEFT (EFT generator)	Haefely	DGFT junior	589071-03	02/02/04	02/01/05
559	Capacitive clamp	ICC	0	0	CNR	N/A

Test Data –Electrical Fast Transient / Burst Test# EFTP-02

Electrically Fast Transient Data									
Complete	<u> X </u>		Job # : 4L0697E		Test # : EFTP-02				
Preliminary	<u> </u>		Page <u> 1 </u>		of <u> 2 </u>				
Client Name :	<u>Vertex RSI</u>								
EUT Name :	<u>CASS Power Drive Unit, VISTA</u>								
EUT Model # :	<u>Model 133 Mount Control System</u>								
EUT Part # :	<u>99-343-2010-01</u>								
EUT Serial # :	<u>001</u>								
EUT Config :	<u>All cabinets powered and all motors running.</u>								
Specification :	<u>EN 61000-6-2</u>				Reference : <u>EN 61000-4-4</u>				
Generator#:	<u>590</u>	Temp. (deg C) :	<u>24</u>	Date :	<u>12/20/05</u>				
Clamp#:	<u>559</u>	Humidity (%) :	<u>36</u>	Time :	<u>3:30</u>				
Probe#:	<u>NA</u>	EUT Voltage :	<u>400Vac</u>	Staff :	<u>J. Fish</u>				
1. L1	<u>X</u>	EUT Frequency :		Photo ID:	<u>4L0697E EFTP-02</u>				
2. L2	<u>X</u>	Phase:	<u>1</u>	Performance Criteria:	<u>B</u>				
3. L3	<u>X</u>	Location:	<u>SAC</u>	Table Top or Floor	<u>Floor</u>				
4. N	<u>X</u>	7. L+N+PE		10					
5. PE	<u>X</u>	8.		11					
6. N+PE		9.		12					

Test Point	EFT Level (kV)	Direct or Capacitive	Polarity	Time Duration	Effects Number	Effects Type	Pass or Fail	Comments:
1	0.5	Direct	+/-	2	0	N/A	Pass	Motor Power
2	0.5	Direct	+/-	2	0	N/A	Pass	
3	0.5	Direct	+/-	2	0	N/A	Pass	
4	0.5	Direct	+/-	2	0	N/A	Pass	
5	0.5	Direct	+/-	2	0	N/A	Pass	
1	1	Direct	+/-	2	0	N/A	Pass	
2	1	Direct	+/-	2	0	N/A	Pass	
3	1	Direct	+/-	2	0	N/A	Pass	
4	1	Direct	+/-	2	0	N/A	Pass	
5	1	Direct	+/-	2	0	N/A	Pass	
1	2	Direct	+/-	2	0	N/A	Pass	
2	2	Direct	+/-	2	0	N/A	Pass	
3	2	Direct	+/-	2	0	N/A	Pass	
4	2	Direct	+/-	2	0	N/A	Pass	
5	2	Direct	+/-	2	0	N/A	Pass	

\\EMCShare\AUTOMATE\DATASHTS\EFT Rev C.xls Document Control #EMC DS IM EFT


Test Data Electrical Fast Transient / Burst Test# EFTP-02 Cont.

Electrically Fast Transient Data									
Complete	<u> X </u>			Job #	<u>4L0697E</u>		Test #	<u>EFTP-02</u>	
Preliminary	<u> </u>			Page	<u>1</u>		of	<u>2</u>	
Client Name :	<u>Vertex RSI</u>								
EUT Name :	<u>AZ/ALT Power Drive Unit, VISTA</u>								
EUT Model # :	<u>Model 133 Mount Control System</u>								
EUT Part # :	<u>99-343-2000-01</u>								
EUT Serial # :	<u>001</u>								
EUT Config :	<u>All cabinets powered and all motors running.</u>								
Specification :	<u>EN 61000-6-2</u>			Reference :	<u>EN 61000-4-4</u>				
Generator#:	<u>590</u>	Temp. (deg C) :	<u>24</u>	Date :	<u>12/20/05</u>				
Clamp#:	<u> </u>	Humidity (%) :	<u>36</u>	Time :	<u>3:30</u>				
Probe#:	<u>800</u>	EUT Voltage :	<u>400Vac</u>	Staff :	<u>J. Fish</u>				
1 L1	<u>X</u>	EUT Frequency :	<u> </u>	Photo ID:	<u>4L0697E EFTP-02</u>				
2 L2	<u>X</u>	Phase:	<u>1</u>	Performance Criteria:	<u>B</u>				
3 L3	<u>X</u>	Location:	<u>SAC</u>	Table Top or Floor	<u>Floor</u>				
4 N	<u>X</u>	7. L+N+PE	<u> </u>	10	<u> </u>				
5 PE	<u>X</u>	8	<u> </u>	11	<u> </u>				
6 N+PE	<u> </u>	9	<u> </u>	12	<u> </u>				

Test Point	EFT Level (kV)	Direct or Capacitive	Polarity	Time Duration	Effects Number	Effects Type	Pass or Fail	Comments:
1	0.5	Direct	+/-	2	0	N/A	Pass	Motor Power
2	0.5	Direct	+/-	2	0	N/A	Pass	
3	0.5	Direct	+/-	2	0	N/A	Pass	
4	0.5	Direct	+/-	2	0	N/A	Pass	
5	0.5	Direct	+/-	2	0	N/A	Pass	
1	1	Direct	+/-	2	0	N/A	Pass	
2	1	Direct	+/-	2	0	N/A	Pass	
3	1	Direct	+/-	2	0	N/A	Pass	
4	1	Direct	+/-	2	0	N/A	Pass	
5	1	Direct	+/-	2	0	N/A	Pass	
1	2	Direct	+/-	2	0	N/A	Pass	
2	2	Direct	+/-	2	0	N/A	Pass	
3	2	Direct	+/-	2	0	N/A	Pass	
4	2	Direct	+/-	2	0	N/A	Pass	
5	2	Direct	+/-	2	0	N/A	Pass	
6	2	Direct	+/-	2	0	N/A	Pass	
7	2	Direct	+/-	2	0	N/A	Pass	

\\EMCShare\AUTOMATED\DATASHTS\EFT Rev C.xls Document Control #EMC DS IM EFT

Test Photographs - Test # EFTP-02



Nemko Dallas, Inc.

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Information:		Test Conditions:	
Test # :	EFTI-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	24°C
Date of Tests:	12/20/05	Humidity:	36%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
590	PEFT (EFT generator)	Haefely	DGFT junior	589071-03	02/02/04	02/01/05
559	Capacitive clamp	ICC	0	0	CNR	N/A

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data –Electrical Fast Transient / Burst Test# EFTI-01

[illegible]

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data Electrical Fast Transient / Burst Test# EFTI-01 Cont.

[illegible]

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data Electrical Fast Transient / Burst Test# EFTI-01 Cont.

[illegible]

Section 11. Surge Immunity

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to electrical surge on supply lines and I/O lines.

Minimum Performance Criteria B

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test # :	SGIP-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	24°C
Date of Tests:	12/20/05	Humidity:	36%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
585	SURGE GENERATOR	HAEFELY	P SURGE 4.1	83070-03	03/30/04	03/30/05

Test Data –Surge Test# SGIP-01**Surge Immunity Test Data**

Complete	<u> X </u>	Job # : 4L0697E	Test # : SGIP-01
Preliminary	<u> </u>	Page <u> 1 </u>	of <u> </u>
Client Name :	Vertex RSI		
EUT Name :	Data Acquisition Unit, VISTA		
EUT Model # :	Model 133 Mount Control System		
EUT Part # :	99-343-3300-01		
EUT Serial # :	001		
EUT Config. :	All cabinets powered and all motors running.		
Specification :	EN 61000-6-2		Reference : EN 61000-4-5
Generator#:	585	Temp (deg C) :	24
Plugin#:		Humidity (%) :	48
		EUT Voltage :	230Vac
		EUT Frequency :	60Hz
		Phase:	1
		Location:	SAC
		Date :	12/20/04
		Time :	1:00
		Staff :	J. Fish
		Photo ID:	4L0697E SGIP-01
		Performance Criteria:	B
		Table Top or Floor:	Table

Coupling			L1-E			L2-E			L1-L2			Comments
Level	Phase	Polarity	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	230Vac
0.5kv	0 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	90 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	180 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	270 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	360 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
1.0kv	0 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	90 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	180 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	270 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	360 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
2.0kv	0 Deg.	+/-	2	0	N/A	2	0	N/A				
	90 Deg.	+/-	2	0	N/A	2	0	N/A				
	180 Deg.	+/-	2	0	N/A	2	0	N/A				
	270 Deg.	+/-	2	0	N/A	2	0	N/A				
	360 Deg.	+/-	2	0	N/A	2	0	N/A				
4.0kv	0 Deg.	+/-										
	90 Deg.	+/-										
	180 Deg.	+/-										
	270 Deg.	+/-										
	360 Deg.	+/-										

..EMCShare\AUTOMATED\DATASHTS\Surge Immunity Rev B.xls Document Control #EMC DS IM SGP

Test Photographs - Test # SGIP-01



Nemko Dallas, Inc.

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Information:		Test Conditions:	
Test # :	SGIP-02	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	24°C
Date of Tests:	12/20/05	Humidity:	36%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
585	SURGE GENERATOR	HAEFELY	P SURGE 4.1	83070-03	03/30/04	03/30/05

Test Data –Surge Test# SGIP-02

Surge Immunity Test Data												
Complete		<u> X </u>		Job # : 4L0697E				Test # : SGIP-02				
Preliminary		<u> </u>		Page <u> 1 </u>				of <u> 2 </u>				
Client Name :		Vertex RSI										
EUT Name :		CASS Power Drive Unit, VISTA										
EUT Model # :		Model 133 Mount Control System										
EUT Part # :		99-343-2010-01										
EUT Serial # :		001										
EUT Config :		All cabinets powered and all motors running.										
		Logic Power										
Specification :		EN 61000-6-2				Reference : EN 61000-4-5						
Generator#:		585		Temp (deg. C) :		24		Date : 12/22/04				
Plugin#:		<u> </u>		Humidity (%) :		48		Time : 9:00				
				EUT Voltage :		230Vac		Staff : J. Fish				
				EUT Frequency :		60Hz		Photo ID. 4L0697E SGIP-02				
				Phase:		1		Performance Criteria: B				
				Location:		SAC		Table Top or Floor: Table				

Coupling			L1-E			L2-E			L1-L2			Comments
Level	Phase	Polarity	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	
0.5kV	0 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	Logic
	90 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	Power
	180 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	270 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	360 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
1.0kV	0 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	90 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	180 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	270 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	360 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
2.0kV	0 Deg.	+/-	2	0	N/A	2	0	N/A				
	90 Deg.	+/-	2	0	N/A	2	0	N/A				
	180 Deg.	+/-	2	0	N/A	2	0	N/A				
	270 Deg.	+/-	2	0	N/A	2	0	N/A				
	360 Deg.	+/-	2	0	N/A	2	0	N/A				
4.0kV	0 Deg.	+/-										
	90 Deg.	+/-										
	180 Deg.	+/-										
	270 Deg.	+/-										
	360 Deg.	+/-										

..EMCShare\AUTOMATED\DATASHTS\Surge Immunity Rev B.xls Document Control #EMC DS IM SGP


Test Data --Surge Test# SGIP-02 - Cont.

Surge Immunity Test Data													
Complete		<u> X </u>		Job # : 4L0697E				Test # : SGIP-02					
Preliminary		<u> </u>		Page <u> 1 </u>				of <u> 2 </u>					
Client Name :		Vertex RSI											
EUT Name :		AZ/ALT Power Drive Unit, VISTA											
EUT Model # :		Model 133 Mount Control System											
EUT Part # :		99-343-2000-01											
EUT Serial # :		001											
EUT Config. :		All cabinets powered and all motors running.											
Specification :		EN 61000-6-2				Reference :				EN 61000-4-5			
Generator# :		585		Temp (deg. C) :		24		Date :		12/22/04			
Plugin# :		<u> </u>		Humidity (%) :		48		Time :		11:30			
				EUT Voltage :		230Vac		Staff :		J. Fish			
				EUT Frequency :		60Hz		Photo ID :		4L0697E SGIP-02			
				Phase :		1		Performance Criteria :		B			
				Location :		SAC		Table Top or Floor :		Table			

Coupling			L1-E			L2-E			L1-L2			Comments
Level	Phase	Polarity	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	230Vac
0.5kv	0 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	Logic
	90 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	Power
	180 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	270 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	360 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
1.0kv	0 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	90 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	180 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	270 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
	360 Deg.	+/-	2	0	N/A	2	0	N/A	2	0	N/A	
2.0kv	0 Deg.	+/-	2	0	N/A	2	0	N/A				
	90 Deg.	+/-	2	0	N/A	2	0	N/A				
	180 Deg.	+/-	2	0	N/A	2	0	N/A				
	270 Deg.	+/-	2	0	N/A	2	0	N/A				
	360 Deg.	+/-	2	0	N/A	2	0	N/A				
4.0kv	0 Deg.	+/-										
	90 Deg.	+/-										
	180 Deg.	+/-										
	270 Deg.	+/-										
	360 Deg.	+/-										

..EMCShare\AUTOMATE\DATASHTS\Surge Immunity Rev B.xls Document Control #EMC DS IM SGP

Test Photographs - Test # SGIP-02



Nemko Dallas, Inc.

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Information:		Test Conditions:	
Test #:	SGIP-03	Test Voltage:	400Vac
Tested By:	J. Fish	Temperature:	24°C
Date of Tests:	12/20/05	Humidity:	36%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria B.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
585	SURGE GENERATOR	HAEFELY	P SURGE 4.1	83070-03	03/30/04	03/30/05

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data –Surge Test# SGIP-03

Surge Immunity Test Data

Complete	X	Job # : 4L0697E	Test # : SGIP-03
Preliminary		Page 1	of 2
Client Name :	Vertex RSI		
EUT Name :	CASS Power Drive Unit, VISTA		
EUT Model # :	Model 133 Mount Control System		
EUT Part # :	99-343-2010-01		
EUT Serial # :	001		
EUT Config :	All cabinets powered and all motors running.		
	Motor Power		
Specification :	EN 61000-6-2		Reference : EN 61000-4-5
Generator#:	649	Temp (deg. C) :	24
Plugin#:	659	Humidity (%) :	48
		EUT Voltage :	400Vac
		EUT Frequency :	
		Phase:	3
		Location:	SAC
		Time : 12/22/04	
		Time : 9:00	
		Staff : J. Fish	
		Photo ID: 4L0697E SGIP-03	
		Performance Criteria: B	
		Table Top or Floor: Table	

[illegible]

..\\EMCShare\\AUTOMATE\\DATASHTS\\Surge Immunity Rev B.xls Document Control #EMC DS IM SGP

Test Data Surge Test# SGIP-03 Cont.

Surge Immunity Test Data											
Complete	<u> X </u>			Job # : 4L0697E	Test # : SGIP-02						
Preliminary	<u> </u>			Page <u> 1 </u>	of <u> 2 </u>						
Client Name :	Vertex RSI										
EUT Name :	AZ/ALT Power Drive Unit, VISTA										
EUT Model # :	Model 133 Mount Control System										
EUT Part # :	99-343-2000-01										
EUT Serial # :	001										
EUT Config :	All cabinets powered and all motors running.										
Motor Power											
Specification :	EN 61000-6-2			Reference :	EN 61000-4-5						
Generator# :	649	Temp. (deg. C) :	24	Date :	12/22/04						
Plugin# :	659	Humidity (%) :	48	Time :	9:00						
		EUT Voltage :	400Vac	Staff :	J. Fish						
		EUT Frequency :		Photo ID :	4L0697E SGIP-03						
		Phase :	3	Performance Criteria :	B						
		Location :	SAC	Table Top or Floor :	Table						

Coupling			L1-E			L2-E			L1-L2			Comments
Level	Phase	Polarity	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	
0.5kV		+/-	5	0	N/A	5	0	N/A	5	0	N/A	Motor
1.0kv		+/-	5	0	N/A	5	0	N/A	5	0	N/A	Power
2.0kv		+/-	5	0	N/A	5	0	N/A	5	0	N/A	
			N-E			L1-L2			L1-L3			
			Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	
0.5kV		+/-	5	0	N/A	5	0	N/A	5	0	N/A	
1.0kv		+/-	5	0	N/A	5	0	N/A	5	0	N/A	
2.0kv		+/-	5	0	N/A							
			L2-L3			L1-N			L2-N			
			Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	
0.5kV		+/-	5	0	N/A	5	0	N/A	5	0	N/A	
1.0kv		+/-	5	0	N/A	5	0	N/A	5	0	N/A	
2.0kv		+/-	5	0	N/A							
			L3-N									
			Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	Surge QTY	Effect QTY	Effect Type	
0.5kV		+/-	5	0	N/A							
1.0kv		+/-	5	0	N/A							

..EMCShare\AUTOMATED\DATASHTS\Surge Immunity Rev B.xls Document Control #EMC DS IM SGP

Section 12. RF Common Mode (A.M.)

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to the electromagnetic fields generated from intentional radiators.

Minimum Performance Criteria A

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test # :	CIPC-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	22°C
Date of Tests:	12/21/04	Humidity:	36%

Test Results:

The E.U.T. complies.

The E.U.T. meets Performance Criteria A.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
411	SIGNAL GENERATOR	MARCONI	2022D	119223029	CNR	N/A
1986	CABLE, 1m	KTL	RG223	N/A	06/09/04	06/09/05
573	CABLE, 5.5m	KTL	RG213	N/A	02/05/04	02/04/05
1080	CABLE, 3m	KTL	RG223	N/A	03/08/04	03/08/05
1553	CABLE 1m	KTL	RG223	N/A	06/09/04	06/09/05
1448	RF amplifier	EIN	3100LA	467	CNR	N/A
718	HP SPECTRUM ANALYZER	HEWLETT PACKARD	8591EM	3639A00980	02/11/04	02/10/05
715	Injection clamp	Fisher	F-140	83	CNR	N/A

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data –R.F. Common Mode (A.M.) Test# CIPC-01

Conducted Immunity Test Data

Complete	<u> X </u>
Preliminary	<u> </u>

Job # 4L0697E Test #: CIPC-01
 Page 1 of 3

Client Name :	Vertex RSI
EUT Name :	Data Acquisition Unit, VISTA
EUT Model # :	Model 133 Mount Control System
EUT Part # :	99-343-3300-01
EUT Serial # :	001
EUT Config. :	All cabinets powered and all motors running.

Specification :	EN 61000-6-2			Reference :	EN 61000-4-6		
Signal Gen #.	411	Temp. (deg. C) :	22	Date :	12/21/04		
Cable#:	1986	Humidity (%) :	36	Time :	8:00		
Cable#:	573	EUT Voltage :		Staff :	J. Fish		
Cable#:	1080	EUT Frequency :		Photo ID:	4L0697E CIPC-01		
Cable#:	1553	Phase:		Performance Criteria:	A		
Cable#:		Location:	SAC	Table Top or Floor:	Floor		
Amp#:	1448	Analyzer#:	718	Sweep rate:			
Amp#:		Clamp#:	715	Step Size:	1%		
				Modulated:	80%		

[illegible]

\\EMCShare\AUTOMATE\DATASHTS\CI Rev C.xls

Document Control #EMC DS IM COND

EQUIPMENT: Model 133 Mount Control System

Conducted Immunity Test Data

[illegible]

Document Control #EMC DS IM COND

& EN61000-6-4: 2001
EN61000-6-2: 2001
REPORT NO.:4L0697EEU1
EQUIPMENT: Model 133 Mount Control System

Conducted Immunity Test Data

Specification :	EN 61000-6-2			Reference :	EN 61000-4-6		
Signal Gen #:	411	Temp. (deg. C) :	22	Date :	12/21/04		
Cable#:	1986	Humidity (%) :	36	Time :	10:00		
Cable#:	573	EUT Voltage :		Staff :	J. Fish		
Cable#:	1080	EUT Frequency :		Photo ID:	4L0697E CIPC-01		
Cable#:	1553	Phase:		Performance Criteria:	A		
Cable#:		Location:	SAC	Table Top or Floor:	Floor		
Amp#:	1448	Analyzer#:	718	Sweep rate:			
Clamp#:		Clamp#:	715	Step Size:	1%		
				Modulated:	80%		

[illegible]

Document Control #EMC DS IM COND

Test Photographs - Test # CIPC-01



Section 13. Magnetic Immunity

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) to magnetic disturbances at power frequency related to industrial installations and power plants.

Minimum Performance Criteria A

This test was not performed for the following reason:

Unit has no components susceptible to a magnetic field.

Section 14. Voltage Dips and Interruptions

Purpose:

The test is intended to demonstrate the compliance of the Equipment Under Test (E.U.T.) when subjected to voltage dips, short interruptions, and voltage variations.

Minimum Performance Criteria B (10ms) and Criteria B (100ms) for voltage dips and Criteria C (5000ms) for voltage interruptions.

Test Method:

See Section 15.

Test Information:		Test Conditions:	
Test # :	VDIP-01	Test Voltage:	230Vac
Tested By:	J. Fish	Temperature:	22°C
Date of Tests:	12/21/04	Humidity:	39%

Test Results:

The E.U.T. complies.

TEST EQUIPMENT

Asset Number	Description	Manufacturer	Model Number	Serial Number	Last Cal	Cal Due
795	SWITCHING AMPLIFIER	ELGAR	SW 5250A	834	05/07/04	05/07/05

& EN61000-6-4: 2001

EN61000-6-2: 2001

REPORT NO.:4L0697EEU1

EQUIPMENT: Model 133 Mount Control System

Test Data –Voltage Dips and Interruptions Test# VDIP-01

[illegible]

EQUIPMENT: Model 133 Mount Control System

Voltage Dips and Interruptions Test Data

Job #: L0697E Test #: VDIP-01
Page 2 of 3

Specification : EN 61000-6-2 Reference :

[illegible]

Document Control #EMC DS IM VDIP

& EN61000-6-4: 2001
EN61000-6-2: 2001
REPORT NO.:4L0697EEU1
EQUIPMENT: Model 133 Mount Control System

Voltage Dips and Interruptions Test Data


Job # : L0697E Test # : VDIP-01
Page 3 of 3

Specification : EN 61000-6-2 Reference :

[illegible]

Document Control #EMC DS IM VDIP

Test Photographs - Test # VDIP-01




Section 15. Test Methods and Block Diagrams.

Conducted Emissions (Mains Ports)

- Applicable Test Standard: EN 61000-6-3, EN 61000-6-4.
- The test set-up is as per the test configuration diagram.
- The E.U.T. is configured as typically used.
- The E.U.T. and any accessories are operated with typical load conditions.
- Conducted powerline measurements are made from 150 kHz to 30 MHz.
- For each current carrying conductor of each power cord associated with the E.U.T., the emission closest to the limit is recorded.
- Final measurements are made using a spectrum analyzer with 10 kHz RBW, peak detector.
- Any emissions that are close to the limit are measured using a test receiver with 10 kHz bandwidth, CISPR quasi-peak detector.
- Bandwidths used on the test receiver are those specified in EN 61000-6-3, EN 61000-6-4

Test Configuration - Powerline Conducted Emissions:




Conducted Emissions (Telecommunication Ports)

Test Method:

- Applicable Test Standard: EN 61000-6-3, EN 61000-6-4
- The test set-up is as per the test configuration diagram and as further defined in EN 61000-6-3, EN 61000-6-4
- The E.U.T. is configured as typically used.
- The E.U.T. and any accessories are operated with typical load conditions. LAN cable measurements may be taken with a LAN utilization in excess of 10%.
- For each telecommunication port, conducted current and/or voltage measurements are made from 150 kHz to 30 MHz.
- Measurements are taken with peak, quasi-peak, and/or average detectors. Quasi-peak and/or average detector measurements take precedence over peak detector measurements.
- Detector bandwidths are those specified in EN 61000-6-3, EN 61000-6-4

Test Configuration:




Radiated Emissions

Test Method - Radiated Emissions:


- Applicable Test Standard: EN 61000-6-3, EN 61000-6-4.
- The test set-up in the shielded room is as per the test configuration diagram.
- The E.U.T. is configured as typically used.
- The E.U.T. and any accessories are operated with typical load conditions.
- Radiated emissions measurements are made from 30 MHz to 1000 MHz.
- The equipment was prescanned in the shielded room using a spectrum analyzer and broadband antenna to produce a list of frequencies to be investigated in the open area test site.
- The equipment is then set-up on an open area test site.
- Variations in antenna height, antenna polarization, and E.U.T. azimuth are explored to produce the emission that has the highest amplitude relative to the limit.
- The frequencies noted in the preliminary test are investigated on the open-air site where amplitude measurements are made.
- If ambient signal field strength is high at 10 meter, the measurements may be performed at 3 meter and extrapolated to the requisite distance.
- All emissions within ± 5 dB of the limit are re-measured using a dipole antenna.
- If less than six emissions are better than 20 dB below limit, the noise level of the measuring instrument at representative frequencies is also reported.
- Any emissions above 1 GHz are measured using a horn antenna and low noise pre-amplifier.

Test Configuration - Radiated Emissions:

Radiated Pre-scan:



Outdoor Test Site for Radiated Emissions:




Electrostatic Discharge

Test Method - Electrostatic Discharge:

- Applicable Test Method: EN61000-4-2: 1995.
- The test set-up is as per the test configuration diagram.
- The electrostatic discharge has been applied to all points and surfaces which are accessible to personnel during normal usage of the E.U.T. (refer to test data table for a listing).
- The generator is re-triggered for a new single discharge.
- This procedure is repeated ten times in each polarity for each point.
- The E.U.T. is exercised during testing.

Test Configuration - Electrostatic Discharge:



The reference ground plane size projects beyond the horizontal coupling plane by at least 0.5 m on all sides.


HCP - Horizontal Coupling Plane VCP - Vertical Coupling Plane RGP - Reference Ground Plane

Radiated Electromagnetic Field (Shielded Room)

Test Method - Radiated Electromagnetic Field (Shielded Room):

- Applicable Test Method: EN61000-4-3: 1997.
- The E.U.T. is placed in the center of the Shielded Room and connected to power and signal leads.
- The test set-up is as per the test configuration diagram.
- The frequency range is swept from 80 to 1000 MHz.
- The modulation is 80% AM with a 1 kHz sinewave.
- The sweep rate is 1.5×10^{-3} decades second or slower.
- The step size is 1% of previous frequency (i.e. previous frequency * 1.01).
- The antenna is rotated in order to test both horizontal and vertical polarization.
- The E.U.T is exercised during testing.

Test Configuration - Radiated Electromagnetic Immunity (Shielded Room)




Electrical Fast Transient/Burst/Surge

Test Method - Electrical Fast Transient/Burst/Surge:

- Applicable Test Method: EN61000-4-4: 1995 and EN61000-4-5: 1995.
- The E.U.T. is configured as shown in the test configuration diagram.
- The waveform is verified before testing commenced.

Test Configuration – Electrical Fast Transient/Burst/Surge:



The EFT/Burst/Surge waveform is directly coupled to the AC mains cable of the E.U.T. via Mains Coupler E4551. EFT/Burst only are indirectly coupled to the data I/O cables via the CCL-4/S Capacitive Clamp.


R.F. Common Mode (A.M)

Test Method - R.F. Common Mode (A.M.):

- Applicable Test Method: EN61000-4-6: 1996.
- The E.U.T. is configured as shown in the test configuration diagram.
- The frequency range is swept from 150 kHz to 80 MHz.
- The disturbance signal is 80% amplitude modulated with a 1 kHz sinewave.
- The rate of sweep is 1.5×10^{-3} decades per second or slower.
- The frequency is incremented at 1% of the start and thereafter 1 % of the preceding frequency value.

Test Configuration - R.F. Common Mode (A.M.):

Setting Immunity Levels:




Magnetic Immunity

Test Method - Magnetic Immunity:

- Applicable Test Method: EN 50082-1: 1997 (EN 61000-4-8: 1993).
- The test set-up is as per the test configuration diagram.
- Power and other functional electrical quantities are applied to the E.U.T.
- Preliminary verification of equipment performance is carried out.
- The continuous magnetic field is applied at 50 Hz.

Test Configuration - Magnetic Immunity:




The current meter is used to calibrate the magnetic field

Voltage Dips and Interruptions

Test Method - Voltage Dips and Interruptions:

- Power to the E.U.T. is varied per the requirements specified in EN61000-4-11.
- The E.U.T. is monitored for normal operation.

Test Configuration – Voltage Dips and Interruptions Tests:




Harmonics

Test Method – Harmonics:

- Applicable Test Method: EN 61000-3-2: 1995.
- The E.U.T. is configured as shown in the test configuration diagram.

Test Configuration – Harmonics:




Flicker

Test Method – Flicker

- Applicable Test Method: EN 61000-3-3: 1995.
- The E.U.T. is configured as shown in the test configuration diagram.
- The equipment is exercised for not less than 5 minutes and not more than 15 minutes.

Test Configuration – Flicker :



Section 16. Performance Criteria.

Date: 12/6/2004

Nemko USE ONLY JOB #:

Company: VertexRSI

MANUFACTURER'S PERFORMANCE CRITERIA

The enclosed Performance Criteria Form is required to be completed before the start of immunity tests. The passing or failing of the test is almost exclusively dependent on the criteria that have been established by the manufacturer. However, some cases are automatic failures such as an unsafe condition that might be caused by an immunity condition or catastrophic failure that requires repair of the product.

Performance criteria have been grouped into three categories, namely A, B, and C:

Performance Criteria A: Normal operation of the EUT is expected.

Please define:

The Azimuth and Altitude test motor will be commanded in Rate Loop mode by the Portable Maintenance Unit, while the Cassegrain motors will be commanded from the LCU test fixture. The Data Acquisition Unit (DAQ) will establish communication with the Host Computer. During these tests, it will be verified that the AZ/ALT/CASS motors remain active and that the DAQ communication link to the Host computer is not lost.

Performance Criteria B: Degradation of product performance is allowed only during the application of the test. No change of stored data is allowed.

Please define:

Degraded performance from Performance Criteria A is allowed (ie fluctuation of motor speed, occasional data link drop-outs, etc.)

Performance Criteria C: Temporary loss of function is allowed as long as the operator can restore proper operation after completion of the test.

Please define:

DAQ data link is lost and AZ/ALT/CASS motors cease movement. DAQ behaves normally after cycling Logic Power to the DAQ/Host Computer. AZ/ALT and CASS Power Drive Units behaves normally after cycling Logic Power and re-enabling the axes from the PMU/LCU Test Fixture.
--

Manufacturer's Representative: Juan C. Delgadillo

Performance Criteria should be as specific as possible. For example:

Criteria A: Green LED indicator ON. Meter reading between 5 and 10.

Criteria B: Meter reading outside the 5 and 10 range but returning to normal range after application of the electromagnetic phenomena. Red LED on would be considered a failure.

Criteria C: Display indicates "error" message. User must press reset button in order for normal operation to continue. EUT behaves normally after the reset button has been depressed.